

# **Fire Sprinkler International 2022 – Antifreeze Solutions in Fire Sprinkler Systems**

June 1, 2022



UL AND THE UL LOGO ARE TRADEMARKS OF UL LLC © 2022. ALL RIGHTS RESERVED. THIS DOCUMENT MAY NOT BE COPIED WITHOUT WRITTEN PERMISSION FROM UL AND ONLY IN ITS ENTIRETY. THE DOCUMENT IS FOR GENERAL INFORMATION PURPOSES ONLY AND IS NOT INTENDED TO CONVEY LEGAL OR OTHER PROFESSIONAL ADVICE. THE INFORMATION PROVIDED IN THIS DOCUMENT IS CORRECT TO THE BEST OF OUR KNOWLEDGE, INFORMATION AND BELIEF AT THE DATE OF ITS PUBLICATION.



# Presenter



Jeff Hebenstreit  
Principal Engineer  
Distinguished Member of Technical Staff  
UL LLC

# Overview of Topics


- History of antifreeze and NFPA standards
- Legacy solution research
- Recent UL research
- Current listing requirements and limitations



# Fire and Explosion in an Apartment Complex Protected by a NFPA 13 Sprinkler System

## General details of fire occurrence


- Fire and explosion occurred in the first-floor apartment of a 12-unit complex in August 2009.
- Sprinkler system was supplied with glycerin antifreeze.
- Fire involving a skillet containing cooking oil and onions originated on the range top.



# Antifreeze in Sprinkler Systems

## Background on the Use of Antifreeze in Sprinkler Systems

- Most common antifreeze solutions historically used were propylene glycol and glycerin which were referenced in NFPA 13 since at least the 1952 edition of the standard.
- Maximum concentration permitted for the glycerin solution was a 70%/30% mix and for propylene glycol it was a 60%/40% mix.



# Legacy Solution Research



- Fire test data summary for residential sprinklers discharging antifreeze mixtures, Underwriters Laboratories Inc., May 26, 2010
- Antifreeze Systems in Home Fire Sprinkler Systems — Literature Review and Research Plan, Fire Protection Research Foundation, June 2010.
- Antifreeze Systems in Home Fire Sprinkler Systems — Phase II Final Report, Fire Protection Research Foundation, December 2010.
- Antifreeze Solutions Supplied through Spray Sprinklers — Final Report, Fire Protection Research Foundation, November 2012.

# Legacy Solution Research

**Scope (see A.5.3.4.4.1(2) of NFPA 25 for summary)**

- **Potential for ignition and substantial contribution to fire of origin**
  - Residential sprinklers (small flammable liquid and cooking oil fires)
  - Residential sprinklers (nominal 1.4 MW exposure)
  - Spray sprinklers (nominal 3.0 MW exposure)
  - *No tests with <50% glycerin and <40% propylene glycol*
- **Firefighting effectiveness**
  - Residential sprinklers (20 tests using actual furniture and simulated furniture arrangements)
  - *No tests conducted with spray sprinklers for light or ordinary occupancy applications*



# Legacy Solution Research – Antifreeze Ignition

## Fire test parameters

- **Test Configuration:** Residential sprinkler discharging onto fire source
- **Liquid Discharged:** 60% PG/40% Water Mixture
- **Fire Source:** 6 in. (15 cm) Wide by 8 ft. (2.4 m) Long Pan of Heptane
- **Sprinkler Type:** Nominal K=3.1 (44) Residential
- **Sprinkler Pressure:** 10 - 80 psig (69 – 550 kPa)
- **Nominal HRR of Fire:** 500 kW
- **Sprinkler to Pan Distance:** 5 ft. (1.5 m)




# Antifreeze in Sprinkler Systems

Fire Protection Research  
Foundation

Antifreeze Solutions in Home  
Fire Sprinkler Systems Phase II

Test A1 - 6" Wide Heptane Pan  
K3.1 Sprinkler  
60% Propylene Glycol  
Antifreeze Solution

# Legacy Research – Residential Fire Tests



L= Coverage length  
W= Coverage width

**Scope** – A total 20 firefighting effectiveness tests using 50 percent glycerin, 40 percent propylene glycol and water

**Results** – Both 50% glycerin and 40% propylene glycol results were comparable to water

# UL 2901 – Antifreeze Solutions

Test	UL Acceptance Criteria Listed Antifreeze Solutions	Test Details	Test Results			
			38% Glycerin	50% Glycerin	30% Propylene Glycol	40% Propylene Glycol
<b>Fire Fighting Effectiveness - Residential Dwelling Units</b>	Temperature acceptance criteria and not more than 2 operated sprinklers	Test 1 – Nominal K=4.9 (70) Pendent Residential Sprinkler, Low Flow	Compliant based upon 50% test results	Compliant	Compliant based upon 40% test results	Compliant
		Test 2 – Nominal K=4.9 (70) Pendent Residential Sprinkler, 100 psig (690 kPa)	Compliant based upon 50% test results	Compliant at 80 and 150 psig (550 and 1030 kPa)	Not Tested - Assumed Compliant based upon glycerin test results	Not Tested - Assumed Compliant based upon glycerin test results
		Test 3 – Nominal K=4.2 (60) Sidewall Residential Sprinkler, Low Flow	Compliant based upon 50% test results	Compliant	Not Tested - Assumed Compliant based upon glycerin test results	Not Tested - Assumed Compliant based upon glycerin test results
		Test 4 – Nominal K=4.2 (60) Sidewall Residential Sprinkler, 100 psig (690 kPa)	Compliant based upon 50% test results	Compliant at 80 and 150 psig (550 and 1030 kPa)	Not Tested - Assumed Compliant based upon glycerin test results	Not Tested - Assumed Compliant based upon glycerin test results

# ANSI/CAN/UL 2901 – Antifreeze Solutions


## Summary

1. Solution characteristics & stability
2. Conductivity and galvanic action potential
3. Material compatibility testing
4. Toxicity
5. **Fire performance**
  - **Exposure to fire**
  - **Firefighting effectiveness**
6. Resistance to leakage
7. Manufacturing and production control
8. Installation instructions



# UL 2901 – Exposure to Fire (Contribution)

Figure 17.2  
Details of Fire Exposure Test Arrangement




Exposure to Fire – 8 ft (2.4 m) Example – Free Burn



# UL 2901 – Exposure to Fire

UL Acceptance Criteria Listed Antifreeze Solutions	Test Details	Test Results			
		38% Glycerin	50% Glycerin	30% Propylene Glycol	40% Propylene Glycol
Not more than a 40 percent increase above the maximum running 15 s average total heat release rate for the nominal 3,000 kW base fire	Test 1 – Nominal K=4.2 (60) SSP, 8 ft (2.4 m) ceiling	Compliant – 24.0% increase	Noncompliant- 84.1 % increase	Compliant - 18.4% increase	Not tested – Assumed Noncompliant based upon 50% glycerin test results
	Test 2 – Nominal K=4.2 (60) SSP, 20 ft (6.1 m) ceiling	Compliant - 26.9% increase	Noncompliant- >230%* increase	Compliant - 8.5% increase	Not tested – Assumed Noncompliant based upon 50% glycerin test results
	Test 3 – Nominal K=8 (115) SSP, 8 ft (2.4 m) ceiling	Compliant - 24.1% increase	Compliant- 28.6 % increase	Compliant - 12.9% increase	Not tested – Assumed Compliant based upon 50% glycerin test results
	Test 4 – Nominal K=8 (115) SSP, 20 ft (6.1 m) ceiling	Compliant - 13.7% increase	Noncompliant - >230%* increase	Compliant - 13.8% increase	Not tested – Assumed Noncompliant based upon 50% glycerin test results

# Recent UL Research – Light Hazard Occupancy



- Automatic Sprinkler – Inner Section - Hydraulically Connected to antifreeze system
- Automatic Sprinkler – Outer Section - Hydraulically Connected to water only system



# Video Comparison of Water and 50% Glycerin



Water at 12.3 psi



50% Glycerin at 13.9 psi

# UL 2901 – Light Hazard Testing Results

UL Acceptance Criteria Listed Antifreeze Solutions	Test Details	Test Results	
		50% Glycerin	Water
<u>Not more than 10 operated sprinklers</u>	<p>Nominal K5.6 (80) SSU</p> <p>14 ft. by 14 ft. (4.3 m by 4.3 m) spacing</p> <p>12.3 psig (85 kPa)</p>	<b>Noncompliant - 12 Operated Sprinklers</b>	<p>Wet System - 4 Operated Sprinklers</p> <p>Dry System - 10 Operated Sprinklers</p>
<u>Not more than 4 operated sprinklers</u>	<p>Nominal K5.6 (80) SSU</p> <p>14 ft. by 14 ft. (4.3 m by 4.3 m) spacing</p> <p>24 psig (165 kPa)</p>	<b>Noncompliant - 7 Operated Sprinklers</b>	Wet System - 2 Operated Sprinklers

# Product iQ™ Database

**UL Product iQ™** SEARCH MY SEARCHES MY TAGS

Dashboard / Search [Help us improve!](#)

▶ 3 Results :: Keyword: vduv :: UL Category Control Number: VDUV

Action ▼ Display: General ▼ Rows: 50 ▼

Document Name	Company Name	UL CCN Description	My Tags
<a href="#">VDUV.EX27967</a>	TYCO FIRE & BUILDING PRODUCTS	Antifreeze Solutions for Use in Fire Sprinkler Systems	
<a href="#">VDUV.EX28039</a>	LUBRIZOL ADVANCED MATERIALS INC	Antifreeze Solutions for Use in Fire Sprinkler Systems	
<a href="#">VDUV.GuidInfo</a>		Antifreeze Solutions for Use in Fire Sprinkler Systems	

< 1 > 1 of 1

**REFINE RESULTS**  
Build or filter your results by keyword and/or adding criteria like document type, file number and country name.

- Keyword**  
vduv Search
- UL Category Control Number**  
× VDUV ×
- Company Name**  
Click to view and filter values
- File Number**  
Click to view and filter values
- Location**  
Click to view and filter values
- + Add Filter**

<https://productiq.ulprospector.com>

## Example limitations

Use Temp Range	Application	Max Volume of Antifreeze in Sprinkler System
-##° F to 150° F  (-##° C to 66° C)	NFPA 13D [1]	≤500 gal (1893L); in accordance with NFPA 13D design criteria
	NFPA 13R – Residential Only (including corridors, garages that serve only a single dwelling unit, and compartmented Ordinary Hazard areas ≤500 ft <sup>2</sup> (46.5 m <sup>2</sup> ) [1]  Where NFPA 13R requires the use of NFPA 13 design criteria, refer to the NFPA 13 applications and volume limitations.	≤500 gal (1893L); in accordance with NFPA 13R design criteria  Where NFPA 13 design criteria is required in areas of an NFPA 13R Occupancy, such as an attic, use the applicable volume limitation for the hazard area for NFPA 13.
	NFPA 13 - Light Hazard [1]	≤200 gal (757 L); in accordance with NFPA 13 design criteria or >200 gal (757 L) to ≤500 gal (1893L); in accordance with NFPA 13 using the dry system hydraulic design criteria, where the system hydraulics are designed as a dry system even though the system is filled with antifreeze.
	NFPA 13 – Ordinary Hazard Groups 1 & 2 [1]	≤40 gal (151 L), in accordance with NFPA 13 design criteria or >40 gal (151 L) to ≤375 gal (1420 L), in accordance with NFPA 13 using the dry system hydraulic design criteria, where the system hydraulics are designed as a dry system even though the system is filled with antifreeze.
	NFPA 13 – Storage [1]	40 gal (151 L); in accordance with NFPA 13 design criteria

# Requirements for Hydraulic Design

- The viscosity of the antifreeze solution at use temperatures shall be considered in the hydraulic design for all systems using antifreeze.
- Hydraulic design and pipe sizing shall be determined using both the Darcy-Weisbach and Hazen-Williams approved hydraulic calculations.
- Because of the density of antifreeze, the K-factor shall be adjusted, and the friction loss shall be considered in the system design.



**Thank You**

Jeff Hebenstreit – [Jeffrey.R.Hebenstreit@ul.com](mailto:Jeffrey.R.Hebenstreit@ul.com)

